

PROPINK® L77 PINK® FIBERGLAS™ LOOSEFILL INSULATION

PROPINK® L77 PINK® Fiberglas™ Loosefill insulation is an alternative to roll or batt insulation in attics, ceilings, walls, and floors for new construction or retrofit applications.

Standards, Codes Compliance

- PROPINK® L77 PINK® Fiberglas™ insulation conforms to the product requirements of ASTM C764 Type I (pneumatic application).
- R-values are determined in accordance with ASTM C687.
- Passes the requirements of ASTM E136 and is considered non-combustible insulation by the model building codes.
- The surface burning characteristics of this product have been determined in accordance with:

| | ULC S 102.2 | ASTM E84 ¹ |
|-----------------|-------------|-----------------------|
| Flame Spread | 0 | 0 |
| Smoke Developed | 0 | 0 |

- PROPINK® L77 PINK® Fiberglas™ insulation is non-corrosive (per ASTM C764, section 12.8)²
- Does not absorb moisture (per ASTM C1104)
- Does not support mold growth (per ASTM C1338)
- · Conforms to the quality standards of the State of California.
- Meets requirements of Minnesota Insulation Standards Program.
- 1 This standard is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled conditions, but does not by itself incorporate all factors required for fire-hazard or fire-risk assessment of the materials, products, or assemblies under actual fire conditions. However, the results of these tests may be used as elements of a fire risk assessment that takes into account all of the factors pertinent to an assessment of the fire hazard of a particular end use. Values are reported to the nearest five (5) rating.

2 Based on ASTM C764, section 12.8 uses the C1617 analytical repeatable test.

Installation Considerations for Enclosed Cavity Applications

When installing PROPINK® L77 PINK® Fiberglas™ insulation in a thermal or acoustical retrofit application, it is absolutely critical that the enclosed cavity crews have a general knowledge of construction and framing principles and a full understanding of the blowing equipment. Additionally, the following items should be considered:

- Check for possible routes that may allow insulation to escape from cavities and fall into the living area, basement, or crawlspace.
- Check exterior siding for signs of paint peeling or moisture problems. If these problems exist, walls should not be insulated until underlying reasons for the problems have been corrected. Insulating a cavity that does not have an adequate interior vapor retarder substantially increases the potential for exterior and/or interior moisture problems.
- Check for HVAC ducts or flues that may be present in wall or floor cavities to be insulated.
- Check for cavity surfaces that may not be able to withstand pressures created during the blowing process.

Installation

Stated R-value is provided by installing the required minimum number of bags per 1,000 net square feet at the specified thickness not less than the label minimum thickness and minimum square foot weight. Installation of the required number of bags may yield more than the specified minimum thickness and minimum square foot weight.

Failure by the installer to provide the specific bag count will result in a lower installed insulation R-value. Owens Corning does not recommend or approve of blending or adding additional materials or adhesives with this product during installation. Owens Corning will accept no responsibilities or liabilities when the product is not installed in accordance with the product label and installation instructions. The installing contractor assumes sole responsibility and liability for proper application.

Attics

Nominal Bag Weight: 32 lbs.

| R-VALUE | MINIMUM INITIAL INSTALLED THICKNESS (IN.) | MINIMUM SETTLED THICKNESS ¹ | MAXIMUM COVERAGE PER BAG (SQ. FT.) | MINIMUM BAGS PER 1,000 SQ. FT. | MINIMUM WEIGHT (LBS. PER SQ. FT.) |
|---------|---|--|---|---|--|
| 13 | 4.75 | 4.75 | 184.6 | 5.4 | 0.173 |
| 19 | 7.00 | 7.00 | 125.0 | 8.0 | 0.256 |
| 22 | 8.00 | 8.00 | 106.3 | 9.4 | 0.301 |
| 26 | 9.25 | 9.25 | 89.6 | 11.2 | 0.357 |
| 30 | 10.50 | 10.50 | 77.0 | 13.0 | 0.416 |
| 38 | 13.25 | 13.25 | 59.9 | 16.7 | 0.534 |
| 44 | 15.00 | 15.00 | 50.7 | 19.7 | 0.631 |
| 49 | 16.75 | 16.75 | 45.0 | 22.2 | 0.711 |
| 60 | 20.00 | 20.00 | 35.8 | 28.0 | 0.895 |

Walls

| R-VALUE | FRAMING | MINIMUM INITIAL INSTALLED THICKNESS (IN.) | INSTALLED DENSITY (LBS. PER CU. FT.) | MAXIMUM COVERAGE PER BAG (SQ. FT.) | MINIMUM BAGS PER 1,000 SQ. FT. | MINIMUM WEIGHT (LBS. PER SQ. FT.) |
|---------|---------|---|---|---|---|--|
| 14 | 2x4 | 3.5 | 1.30 | 84.4 | 11.8 | 0.379 |
| 15 | 2x4 | 3.5 | 1.95 | 56.3 | 17.8 | 0.569 |
| 22 | 2x6 | 5.5 | 1.30 | 53.7 | 18.6 | 0.596 |
| 23 | 2x6 | 5.5 | 1.50 | 46.5 | 21.5 | 0.688 |
| 24 | 2x6 | 5.5 | 2.25 | 31.0 | 32.2 | 1.031 |

Floors

| R-VALUE | FRAMING | MINIMUM INITIAL INSTALLED THICKNESS (IN.) | INSTALLED DENSITY (LBS. PER CU. FT.) | MAXIMUM COVERAGE PER BAG (SQ. FT.) | MINIMUM BAGS PER 1,000 SQ. FT. | MINIMUM WEIGHT (LBS. PER SQ. FT.) |
|---------|---------|--|---|---|---|--|
| 31 | 2x8 | 7.25 | 1.8 | 29.4 | 34.0 | 1.088 |
| 40 | 2x10 | 9.25 | 2.0 | 20.8 | 48.2 | 1.542 |
| 48 | 2x12 | 11.25 | 1.9 | 18 | 55.7 | 1.781 |

Cathedral Ceiling²

| R-VALUE | FRAMING | MINIMUM INITIAL INSTALLED THICKNESS (IN.) | INSTALLED DENSITY (LBS. PER CU. FT.) | MAXIMUM COVERAGE PER BAG (SQ. FT.) | MINIMUM BAGS PER 1,000 SQ. FT. | MINIMUM WEIGHT (LBS. PER SQ. FT.) |
|---------|---------|--|---|---|---|--|
| 30 | 2x8 | 7.25 | 1.35 | 39.2 | 25.5 | 0.816 |
| 38 | 2x10 | 9.25 | 1.35 | 30.8 | 32.5 | 1.041 |
| 49 | 2x12 | 11.25 | 2.20 | 15.5 | 64.5 | 2.063 |
| 49 | 2x12* | 12.0 | 1.50 | 21.3 | 46.9 | 1.5 |

- 1 This product shows negligible settling.
- 2 Raft-R-Mate baffles should be installed in the underside of the roof deck in each rafter cavity, from eave to ridge, to provide required ventilation.
- * The cavity depth is increased to a full 12" by adding a 1x2 furring strip (actual size 3/4" x 1.5")

A Volu-Matic SE insulation blowing machine was used to determine the coverage information. The machine was set up in 3rd gear, with a 12-inch gate opening, 1.4 psi air bleed pressure, and 100 feet of 4-inch plus 50 feet of 3.5-inch Mark 2 hose, blowing the material out in a 10-foot arc.

Mid-Floors

| MINIMUM INITIAL INSTALLED THICKNESS (IN.) | INSTALLED DENSITY (LBS./CU.FT.) | MAXIMUM COVERAGE PER BAG (SQ.FT.) | MINIMUM BAGS PER 1,000 SQ. FT. | MINIMUM WEIGHT (LBS./SQ. FT.) |
|---|---------------------------------------|---|--------------------------------------|-------------------------------------|
| 12 | 0.7 | 45.7 | 21.9 | 0.7 |
| 12 | 0.8 | 40.0 | 25.0 | 0.8 |
| 12 | 0.9 | 35.6 | 28.1 | 0.9 |
| 14 | 0.7 | 39.2 | 25.5 | 0.8 |
| 14 | 0.8 | 34.3 | 29.2 | 0.9 |
| 14 | 0.9 | 30.5 | 32.8 | 1.1 |
| 16 | 0.7 | 34.3 | 29.2 | 0.9 |
| 16 | 0.8 | 30.0 | 33.3 | 1.1 |
| 16 | 0.9 | 26.7 | 37.5 | 1.2 |
| 18 | 0.7 | 30.5 | 32.8 | 1.1 |
| 18 | 0.8 | 26.7 | 37.5 | 1.2 |
| 18 | 0.9 | 23.7 | 42.2 | 1.4 |
| 20 | 0.7 | 27.4 | 36.5 | 1.2 |
| 20 | 0.8 | 24.0 | 41.7 | 1.3 |
| 20 | 0.9 | 21.3 | 46.9 | 1.5 |
| 22 | 0.7 | 24.9 | 40.1 | 1.3 |
| 22 | 0.8 | 21.8 | 45.8 | 1.5 |
| 22 | 0.9 | 19.4 | 51.6 | 1.7 |
| 24 | 0.7 | 22.9 | 43.8 | 1.4 |
| 24 | 0.8 | 20.0 | 50.0 | 1.6 |
| 24 | 0.9 | 17.8 | 56.3 | 1.8 |
| 30 | 0.8 | 16.0 | 62.5 | 2.0 |
| 30 | 0.9 | 14.2 | 70.3 | 2.3 |
| 30 | 1.0 | 12.8 | 78.1 | 2.5 |
| 36 | 0.8 | 13.3 | 75.0 | 2.4 |
| 36 | 0.9 | 11.9 | 84.4 | 2.7 |
| 36 | 1.0 | 10.7 | 93.8 | 3.0 |
| 40 | 0.9 | 10.7 | 93.8 | 3.0 |
| 40 | 1.0 | 9.6 | 104.2 | 3.3 |
| 40 | 1.1 | 8.7 | 114.6 | 3.7 |
| 42 | 0.9 | 10.2 | 98.4 | 3.2 |
| 42 | 1 | 9.1 | 109.4 | 3.5 |
| 42 | 1.1 | 8.3 | 120.3 | 3.9 |
| 44 | 0.9 | 9.7 | 103.1 | 3.3 |
| 44 | 1 | 8.7 | 114.6 | 3.7 |
| 44 | 1.1 | 7.9 | 126.0 | 4.0 |
| 46 | 0.9 | 9.3 | 107.8 | 3.5 |
| 46 | 1 | 8.3 | 119.8 | 3.8 |
| 46 | 1.1 | 7.6 | 131.8 | 4.2 |
| 48 | 0.9 | 8.9 | 112.5 | 3.6 |
| 48 | 1 | 8.0 | 125.0 | 4.0 |
| 48 | 1.1 | 7.3 | 137.5 | 4.4 |

Fiberglass Insulation and Mold

As manufactured, fiberglass insulation is resistant to mold growth. However, mold growth can occur on building materials, including insulation, when it becomes contaminated with organic material and when water is present.

To avoid mold growth on Fiberglas™ insulation, remove any water that has accumulated, and correct or repair the source of that water as soon as possible. Insulation that has become wet should be inspected for evidence of residual moisture and contamination, and any insulation that is contaminated should be promptly removed and replaced.

Fire Hazard

To prevent fire or overheating of recessed light fixtures or similar electrical devices, do not insulate on top of or within 3 inches of such devices unless they are specifically approved to be covered by insulation (labeled with "IC" rating). Do not place insulation in air spaces surrounding metal flues, chimneys, or fireplaces. Provide minimum clearances specified in NFPA-31, NFPA-54, or NFPA-211, or as required by local building codes. For high efficiency appliances that use PVC pipe for exhaust and intake, follow that manufacturer's recommendations for insulating.

Caution: May cause temporary irritation to the skin, eyes, and respiratory tract. Avoid contact with eyes and skin. Wear long-sleeved, loose-fitting clothing, gloves, and eye protection when handling and applying material. Wash with soap and warm water after handling. Wash work clothes separately, and wipe out washer.

Environmental and Sustainability

Owens Corning is a worldwide leader in building material systems, insulation, and composite solutions, delivering a broad range of high-quality products and services. Owens Corning is committed to driving sustainability by delivering solutions, transforming markets, and enhancing lives. More information can be found at www.owenscorning.com.

Certifications and Sustainable Features

- GREENGUARD Certified products are certified to GREENGUARD standards for low chemical emissions into indoor air during product usage.
 For more information, visit ul.com/gg.
- Environmental Product Declaration (EPD) has been certified by UL Environment.*
- ENERGY STAR and the ENERGY STAR mark are registered trademarks of the U.S. Environmental Protection Agency.







Disclaimer of Liability

Technical information contained herein is furnished without charge or obligation and is given and accepted at recipient's sole risk. Because conditions of use may vary and are beyond our control, Owens Corning makes no representation about, and is not responsible or liable for, the accuracy or reliability of data associated with particular uses of any product described herein.

LEED® is a registered trademark of the U.S. Green Building Council.

Notes

For additional information, refer to the Safe Use Instruction Sheet (SUIS) found in the SDS Database via http://sds.owenscorning.com.

OWENS CORNING INSULATING SYSTEMS, LLC

ONE OWENS CORNING PARKWAY TOLEDO, OH 43659 USA

1-800-GET-PINK® www.owenscorning.com

Pub. No. 43942-V. Printed in U.S.A. December 2025. The color PINK is a registered trademark of Owens Corning. © 2025 Owens Corning. All Rights Reserved.